

Luke Schroeder

Lead Consulting and Inspection, Inc.

N.J. Dept. of Health Lead Permits
Inspector/Risk Assessor #001615
Plan/Designer #001609
Supervisor/Housing & Public Building #001537
Supervisor/Commercial Bldg., & Steel Structures #007837
NJ Dept. of Community Affairs Lic. #00121-E

Lead Certification

Name: Friends West State Child Development
1201 West State Street
Trenton, NJ 08618
Phone:

Inspection Address: 1201 West State Street
Trenton, NJ 08618

Inspection date: May 28, 2014

Certification:

| | |
|-----------------|------------------|
| Interior | Lead Free |
| Exterior | Lead Free |

Comments:

“Lead-base paint” means paint or other surface coating material that contains lead equal to or in excess of 1.0 milligrams per centimeter squared or in excess of 0.5 percent by weight, or such other level as may be established by Federal law.

“Lead-Free” means having no lead-based paint on any surface within a dwelling unit, common area or building.

“Lead-Hazard free” means the absence of any condition that causes exposure to lead from lead-contaminated dust, lead-contaminated soil, or lead-contaminated paint that is deteriorated or present in accessible surfaces, friction surfaces, or impact surfaces that would result in adverse human health effects.

“Lead Safe” means the absence of lead-contaminated dust from any accessible or impact surfaces that contain lead-base paint.

“Lead-based paint hazard” means any condition that causes exposure to lead from lead-contaminated dust or soil or lead-contaminated paint that is deteriorated or present in surfaces that would result in adverse human health effects.

On-going evaluation and maintenance is required to ensure that painted surfaces that contain lead-base paint remain intact and in a hazard free or lead safe condition.

Certification is for specified areas tested as listed in report at time of inspection.

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537